

VE Option 1:

Contractor shall replace roof system, but retain existing thermal layer boards.

Contractor shall provide 4" minimum rigid insulation board, mechanically attached, as overlay to existing thermal layer boards. At areas where abandoned mechanical openings are covered as mentioned in addendum, rigid insulation thickness shall match existing thermal layer boards plus 4" minimum.

VE option 2:

Contractor shall replace pyranic coating with silver coating.