



RFP 687-16P Heating Valve & Actuator Replacement

Addendum 001
Issued
January 27, 2016

Below are the questions we have received from various parties with respect to this Request for Proposal, along with our response (indicated in red font). Although we have endeavored to remove duplicate questions, we have presented the questions below in an unedited format. We hope this is helpful to you in preparing your proposal. Please remember that bids are due by 2:00 p.m. Mountain Time on 2/11/16. This addendum is number 001. Please follow the submittal instructions carefully when submitting your proposal. CMC is not able to accept a late submittal. Remember to allow a few extra minutes for any technical difficulties; all bids will be received at bids.coloradomtn.edu.

1. For clarification purposes of the heating valve and cooling valve count;

Heating Valves

·	Qty 132	Rooms- One (1) , 2 way valve per room =	Quantity 132-	2
		way heating valves		
·	Qty 2	Air Handling Units in the crawlspace=	Quantity 2-	3
		way heating valves		
·	Qty 1	Make Up Air Unit	Quantity 1-	3
		way heating valve		
<u>Total Count (132) 2 way heating valves</u>				
<u>(3) 3 way heating valves</u>				

Cooling Valves

·	Qty 123	2 way valve =	Quantity 123-	2
		way cooling valves		
·	Qty 2	Air Handling Units in the crawlspace=	Quantity 2-	3
		way cooling valves		
·	Qty 10	Shelf Stock	Quantity 10	2
		way heating valves		
<u>Total Count (133) 2 way cooling valves</u>				
<u>(2) 3 way cooling valves</u>				

Is this the correct valve count ? **Yes**

2. Do you guys want us to include signed copy of the RFP document provided by you. I know some institutions want that to be included in the proposal package. **Your signed proposal is enough.**

3. Could you please clarify if we should include draining and refilling the entire building and also purging air from the system in our bid for this one? **Yes, include draining, refilling and bleed the system.**