



RFP 710-16P Vet. Tech. Water Line

Addendum 001
Issued May 26th, 2016

Amended Due Date:

Due to a delay in the Questions Answered we are extending the Request for Proposal Due date to May 31st, 2016 at 2:00p.m. Please see the amended dates in red below.

TIMELINE	DATE	TIME
Issue date	05/02/16	4:00 p.m.
Pre-Proposal Walkthrough	05/13/16	1:00 p.m.
Questions and Clarifications Due (bids@coloradomtn.edu)	05/18/16	2:00 p.m.
Questions Answered	05/26/16	4:00 p.m.
Request for Proposals (RFP) Due (bids@coloradomtn.edu)	05/31/16	2:00 p.m.
Short List of Vendors Announced	06/03/16	4:00 p.m.
Candidate Interview (if necessary – save the date)	06/09/16	TBD
Target Award Date (Subject to Change)	06/14/16	4:00 p.m.

Below are the questions we have received from various parties with respect to this Request for Proposal, along with our response (indicated in red font). We have presented the questions below in an unedited format. We hope this is helpful to you in preparing your proposal. Please remember that bids are due by 2:00 p.m. Mountain Time on 5/31/16. This addendum is number 001. Please follow the submittal instructions carefully when submitting your proposal. CMC is not able to accept a late submittal. Remember to allow a few extra minutes for any technical difficulties all bids will be received at bids@coloradomtn.edu.

1. Which back flow preventer do you prefer, the built in type or the type that screws onto the nozzle of the hydrant?

Nozzle on the hydrant

Responses to questions during Pre-Proposal Walkthrough on 5/13/16

1. There is no leech field however there is a septic tank that is used as a separator for dog hair from the dog kennel and a sewer line leaving the tank
2. Need to locate phones (underground per campus), fiber optic line, and water line to lab building
3. Need curb stop at tie in at 8” DIP and at every yard hydrant
4. No sprinklers in the area you are cutting