



RFQ #732-16
Cathodic Protection for Water Tank

Addendum 001
Issued 11/9/2016

Can you provide the submittal documents and drawings for your existing 1,000,000 gallon tank? To properly size the cathodic system we need to understand the actual dimensions of the tank, steel thickness, floor type, foundation design (with the amount of steel in the foundation).

Please see the Operational and Maintenance Book posted to the CMC website with this addendum.

Do you have conductivity/resistivity information on the water that is being stored in the tank?

No.

When would Colorado Mountain College like the installation of the cathodic system to be installed?

Installation can happen as soon as students leave for the summer. Commencement is scheduled for May 6, 2017.