



RFP #783-18

Replacement Boilers – Bristol Hall - Steamboat Springs

Addendum 001

Issued February 20, 2018

1. It is my understanding the normal system pressure is 30 PSI? If so this would require the expansion tanks to be upgraded to bladder style ASME tanks.

Yes.

2. Could we get the length and diameter of the existing tanks?

Tank #1 - 60"x22"

Tank #2 - 74"x18"

3. What is the voltage and breaker size of the existing boiler pumps and boilers?

Square D Breakers - 10 amp. 120v