


Summary of Submittal changes



Jeff Johnson
Architectural PC

136 East Third Street
Suite B
Rifle, CO 81650

PHONE 970-625-0580

JEFF JOHNSON

Owner/Architect

jjarch@rof.net

Colorado Mountain College Dillon Campus ADA Entry Vestibule

Sheet DE1:

Code Summary, under Governing Code:
Changed "2014 NEC" to read "2017 NEC"

Code Summary, under Existing Construction Type
Changed "Type III-B" to read "Type V-B"

This is the construction type as listed in previous permits for this building:

- roof permit # P-0021647 filed in September 2017
- roof permit filed August 2015

General Notes:

Last note addresses Energy Code Compliance and method and R values

Building Occupancy Calculations added to determine occupant load on new exterior door.

Internal ADA button operated door, frame and wall has been removed.

Load bearing exterior wall "WE6.1"; with construction type V-B,
is not required to be non-combustible.

Exit door out of new vestibule width changed from 36" wide to 42" wide
(in reference to occupant load serviced)

Sheet DE2:

Exit door vision lite lowered to comply with A117.1/ 404.2.10

ADA identification sign height compliance clarified

Roof assembly and Wall assembly R-Value listed per C402.1.3

Screened soffit vents noted, net square inches comply with IBC 1203.2

Sheet S1.1:

Slab thickness changed to 5" to allow rebar clearance

Rigid insulation graphically shown to extend to top of slab

Addition:

Door Hardware specification section 8710, including compliance parameters
of panic hardware.