



RFP #790-18 Security Film

**Addendum 001
Issued March 26, 2018**

1. Due to the vast array, and quality of security window film products on the market, will Colorado Mountain College require that the proposed window films meet certain specifications, and performance standards for the following:
 - a. Tensile strength
 - b. Break strength
 - c. Graves Tear

Yes, we will want the films to meet certain specifications and we ask that the bidders submit that information and their recommendation for a high end product, middle grade product and lower end product.

2. In regards to the wet glaze, what performance standard is Colorado Mountain College looking to achieve, i.e. a windstorm standard of 3/8 inch, or the blast mitigation standard of 1/2 inch of silicone attachment?

Blast mitigation standard.

3. Will any portions of this project require a prevailing wage for the labor?

No.