

Sopris Residence Hall Statement of Work

3-19-18

Electrical & Lighting

Remove and recycle:

- (60) 2 by 2 fluorescent fixtures.
- (31) 2 by 4 fluorescent fixtures.
- (15) 1 by 4 two lamp fluorescent fixtures.

Electrical & Lighting

Install owner provided fixtures:

- (60) 2 by 2 LED flat panel fixtures with custom fit to be flush (trim around lights to be installed by owners).

- (45) Emergency light ballasts (every other light in hallways). Emergency ballasts provided by owners.

- Custom fit and adjust (42) existing 2 by 2 LED lights to fit flush with ceiling (trim around lights to be installed by owners).

Electrical & Lighting

Provide and install (use comparable fixture as specified in Calaway spec sheet):

- (10) 2 by 4 LED flat panel with emergency ballast and flush mount kit in stairwells.
- (21) 2 by 4 LED flat panel for grid ceiling in study lounges, art room, laundry, office and some in stairwells.
- (15) 1 by 4 LED lights in mech rooms, bathroom, elevator room and custodial closets.