



RFP #797-18
GOL! General Contractor

Addendum 001
Issued June 7, 2018

1. Can you please provide more information/specifications on the metal wall panels and metal roofing?

We are matching the existing Climax Building exterior siding.

The material is:

- Siding: Berridge exposed fastener, metal siding R-Panel, 22 guage, White Color – or equal product.
- Roof: Berridge Tee-Panel, Snap-on seam cap, 24 guage, white color – or equal product.