



RFP #836-19P Quigley Roof Replacement

**Addendum 004
Issued March 5, 2019**

Below is description and estimated depths of core material. LR = Lower Roof and TR = Top Roof. Let me know if you need anything else.

Roof Core Makeup, both samples approx. 1 ft thick

Lower Roof:

- ¼ inch asphalt roofing material
- ½ inch brown fibrous board
- ¼ inch black roofing/with tar
- ½ inch brown fibrous board
- 3 inches foam
- ½ inch brown fibrous board
- ¼ inch black tar

Top Roof:

- ½ inch gravel
- ¼ inch black roofing/with tar
- ¼ inch black roofing/with tar - Asbestos layer
- 3 inches foam
- ¼ inch black fibrous tar