



RFQ #874-19Q **Self-Contained Breathing Apparatus**

Addendum 002
Issued December 20, 2019

1. Are you requesting two bottles per scba?

1 bottle per SCBA.
2. Are you requesting 30 minute duration or would you prefer 45 minute?

30 minute bottles.
3. What pressure are you wanting the SCBA? 2216 psi, 4500 psi, or 5500psi?

Prefer 4500 psi.
4. Are you requesting quick connect regulator?

Yes.
5. Are you requesting Snap Change cylinder connection to SCBA?

We do not need snap change connection. It can be a threaded connection.