



RFP #880-20P Hill Hall Exterior Painting

**Addendum 002
Issued February 19, 2020**

1. We operate a pressure washing company and we are wondering if there is a possibility to bid just the pressure washing of the exterior of the building only?

We do not want to bid this out separately.

2. What type of caulking is to be used around the windows and doors?

100% clear silicone caulk, waterproof, mold and mildew resistant.

3. Are we able to use a sky track on the grounds or just ladders?

Yes, a lift can be used in the back, front and the east side of the building. The west and south sides would be too tight of an area.

4. Paint Specifications

Wood

SW Rejuvenate Siding Restoration (Equal or Better)

Metal

SW Exterior Acrylic Latex (Equal or Better)

Colors

SW7046 - Anonymous will replace the red color.

SW7037 – Balanced Beige will replace the lighter color.

Flashing will remain the same color brown.